



No : JMC/S.W.M /38/N.O.C/923 /2024-25.
Dt. 04/12/2024.

:: CERTIFICATE ::

This is to certify that G. D. GOENKA PUBLIC SCHOOL situated near Haria College, Indira Gandhi Marg, Jamnagar who has sanitation system has appropriate means of disposing the waste water. The building has separate facility for drinking water and daily usage. R.O. plant has been installed for pure drinking water. Taking all this into consideration Health & Sanitation Certificate is issued to G. D. GOENKA PUBLIC SCHOOL.

This certificate is issued as per the application of G. D. GOENKA PUBLIC SCHOOL.

THIS CERTIFICATE IS VALID UPTO ONE YEAR FROM THE DATE OF THE ISSUE.

Due date for renewal : Dt.03-12-2025.


Place : Jamnagar.

Date : 04-12-2024.



G. D. Goenka Public School, Jamnagar

Principal


Zonal Officer/
Chief Sanitary Inspector
Solid Waste Management Dept.
Jamnagar Municipal Corporation



G. D. Goenka Public School

Director



GUJARAT WATER SUPPLY & SEWERAGE BOARD
JAL BHAVAN, SARU SECTION ROAD
JAMNAGAR



REPORT ON BACTERIOLOGICAL EXAMINATION OF WATER

Name & Address

GD GOENKA PUBLIC SCHOOL
NR.HARIA COLLEGE,INDIRA GANDHI ROAD
JAMNAGAR

Sender's Ref. No: NIL
Date of Collection : 19-11-2024
Date of Receipt at Lab.: 19-11-2024
Sample collected by : SENDER

Lab Ref. i.e. JBW No.

1090

Date of Completion Examination

21-11-2024

Source of Water Sample

GROUND WATER

Source Details

RO WATER FROM TUBE WELL AT GD GOENKA PUBLIC SCHOOL

Village

JAMNAGAR

Habitation

JAMNAGAR

Taluka

JAMNAGAR

District

JAMNAGAR

APHA, AWWA, 9221-D Presence - Absence Coliform Test, @ 37° C

-

APHA, AWWA, 9221-F Presence - Absence E-Coli Test, @ 44° C

-

MPN OF Coliform: Per 100 ml of Sample at 37° C

<2

MPN of Faecal Coliform per 100 ml of Sample at 44° C

<2

Free Chlorine (PPM)

0.1

OPINION FOR POTABILITY

FIT

Important Note:-

1) '>=' Indicates greater than or equal to, 2) '<' Indicates less than

NOTE : Table - 6 Bacteriological Quality of Drinking Water (BIS:10500:2012) : Second Revision.

② All Water Intended for Drinking -

(a) E.coli or Thermotolerant coliform bacteria shall not be detectable in any 100ml sample.

@ Treated Water Entering the Distribution system & Treated Water in the Distribution system -

(a) E.coli or Thermotolerant coliform bacteria shall not be detectable in any 100ml sample.

(b) Total coliform bacteria shall not be detectable in any 100ml sample.

@ 0.2ppm Free Residual Chlorine at consumer end is recommended.

1) Test Report is issued for assessing Bacteriological Fitness as per the BIS 10500:2012 for the given Drinking Water Sample only.

2) This Report should not be taken as a basis to getting license from any Government authority.

3) After Collection of Bact. Sample, it must be preserved at 4°C and submitted to laboratory within 24hrs.

(Microbiologist)

Chemical Sample Lab Reference No :-

GJTI /Dist. Lab / BWT / 913 / of 2024 DATE: 21/11/24

G. D. Goenka Public School, Jamnagar

[Signature]
Principal



G. D. Goenka Public School
[Signature]
Director



Laboratory In Charge,
District Laboratory,
G.W.S. & S.B.
"JAL BHAVAN",
Saru Section Road,
JAMNAGAR - 361002
Phone : (0288)2550253



Name & Address of Customer:-

GD GOENKA PUBLIC SCHOOL
NR.HARIA COLLEGE,
INDIRA GANDHI ROAD
JAMNAGAR

Customer Reference No.:

NIL

Sample Submitted by :

SENDER

Date of Sample Receipt :

19-11-2024

Analysis Starting Date :

19-11-2024

Analysis Completion Date :

20-11-2024

ULR No.:

TC75142400000623F

Discipline : Chemical Testing, Group: Water

Test Report No.:	437/2024-25	Date of Issue :	21-11-2024
Sample ID :	JCW-437/11/2024	Mode of Sample:	
Main Source :	GROUND WATER	Source :	TREATED WATER
Location :	RO WATER FROM TUBE WELL AT GD GOENKA PUBLIC SCHOOL		
Village :	JAMNAGAR	Habitation :	JAMNAGAR
Taluka :	JAMNAGAR	District :	JAMNAGAR
Latitude :		Longitude :	
Kindly find herewith the Analytical Results.		Sample Type: Drinking Water	
Sr. No.	Parameter	Unit	Analytical Value
1	Colour	Hazen	1
2	Turbidity	NTU	1.23
3	pH at 25°C	-	7.23
4	Conductivity at 25°C	µS/cm	669
5	Total Dissolved Solids	mg/l	428
6	Total Hardness (as CaCO ₃)	mg/l	224
7	Calcium (as Ca+2)	mg/l	54
8	Magnesium (as Mg+2)	mg/l	22
9	Chloride (as Cl-)	mg/l	136
10	Sulphate (as SO ₄ -2)	mg/l	38
11	Nitrate (as NO ₃ -)	mg/l	22.04
12	Fluoride (as F-)	mg/l	0.28
13	Total Alkalinity (as CaCO ₃)	mg/l	120

This Report is issued under the following terms & Condition :

1. This report is referring only to the tested sample and for applicable parameter.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part, and can't be used be as evidence in court of law.
4. Please refer back page for IS 10500:2012 (2nd Revision) limits.

Reviewed By :

(R. R. RATHOD)

Chemist & Technical Manager

Authorized By:

(N. M. SAMA)

Quality Manager

End of the Test Report

O.W. No. DLJ/437/1 of 2024, Date :- 21/11/24

Ground Floor, "Jalbhavan", Saru Section Road, Jamnagar-361002

Phone No.:- (0288) 2550253, E-mail: distlabjam@gmail.com

G. D. Goenka Public School, Jamnagar

Principal

G. D. Goenka Public School
Director